



# **Standard for Power Quality and Reliability in Electric Power Systems**

Statement of Results and Final Decision

ES 09/2023

Publication Date: 21 December 2023

**Contents**

- 1. Introduction ..... 4
  - 1.1 Background..... 4
  - 1.2 Structure of the remainder of the Document..... 6
- 2. URCA’s responses to Comments received on the Consultation..... 7
  - 2.1 General Comments..... 7
  - 2.2 Specific Responses to the Consultation Questions ..... 8
- 3. Conclusions and Next Steps ..... 16
  - Annex A: Standard for Power Quality and Reliability in Electric Power Systems ..... 17**
  - 1. Regulatory Title ..... 17
  - 2. Definitions ..... 17
  - 3. Measurement and Enforcement..... 19
    - 3.1 Measurement Regime ..... 19
    - 3.2 Equipment ..... 19
    - 3.3 Enforcement..... 20
    - 3.4 Inspections ..... 21
  - 4. Nominal Supply Levels ..... 21
  - 5. Allowable Deviation to Nominal Supply Levels..... 22
    - 5.1 Voltage Deviation ..... 22
    - 5.2 Allowable Voltage Phase Imbalance ..... 22
    - 5.3 Frequency Deviation ..... 23
    - 5.4 Harmonic Deviation..... 23
  - 6. Reliability..... 25
    - 6.1 Definitions, acronyms, and abbreviations..... 25

6.2	Recording and Reporting of Indices .....	26
6.3	Reliability Indices.....	26
6.4	Sample Calculations of SAIFI, SAIDI and CAIDI .....	28
6.5	Quality of Service Standards for Reliability .....	31
	<b>Annex B: Submissions Received to the Public Consultation ES 06/2023 .....</b>	<b>32</b>

# 1. Introduction

The Utilities Regulation and Competition Authority (“URCA”) is empowered to issue technical rules and standards to advance the sector policy objectives.<sup>1</sup> This includes, but is not limited to, standards of service, quality and safety of electricity service and equipment for the protection of electricity consumers.<sup>2</sup> Electricity suppliers are required to incorporate such standards in their consumer protection plans.<sup>3</sup>

This Statement of Results and Final Decision;

- i. provides a background and high-level summary URCA’s proposal concerning the Standard for Power Quality and Reliability in Electric Power Systems
- ii. summarizes the written submissions received to the public consultation on the Standard for Power Quality and Reliability in Electric Power Systems, (ES 06/2023) issued on 27 September 2023 (the "Consultation Document"),
- iii. provides URCA’s analysis of and response to the submissions made, and
- iv. sets out URCA’s Final Decision.

## 1.1 Background

URCA is the independent regulator for the Electricity Sector (“ES”) in The Bahamas. URCA is responsible for the licensing of all generation, transmission, distribution and supply of electricity within, into, from or through The Bahamas. URCA regulates the ES through the Electricity Act, 2015 (“EA 2015”), which establishes, inter alia, URCA’s powers and obligations in relation to the regulation of the ES.

The electricity sector policy and objectives, as set out in the EA 2015, mandate that the production of electricity be subject to a regime that ensures the supply of safe, least cost, reliable and environmentally sustainable electricity throughout The Bahamas. URCA’s primary role is the

---

<sup>1</sup> Electricity Act, 2015, section 38(3)(g)

<sup>2</sup> Electricity Act, 2015, section 40(2)(a)

<sup>3</sup> Electricity Act, 2015, section 40(1)

regulation of the electricity sector in accordance with the goals, objectives and principles underpinning the national energy and electricity sector policies.

URCA believes that a reliable supply of electricity is one that is both consistently available and of good quality. Such a supply is one that will lead to consumer confidence and trust.

In fulfilling the EA mandate, URCA is cognizant of the fact that the production of electricity inherently carries the risk of variations in the ideal (nominal) value that is intended to be produced by the electricity supplier (quality) as well as variations in the consistency of supply (reliability). URCA also notes that these variations can have disruptive effects on equipment connected to the electricity grid, such as motors and timers or other frequency or voltage sensitive devices. To mitigate this risk, URCA is establishing a standard that outlines the parameters for electricity supply.

Section 78 of the EA 2015 repealed The Electricity Act (Ch. 194) and the Out Islands Electricity Act (Ch. 195). The legislation at that time included supply standards for voltage and frequency. These standards were not explicitly included in the legislation that replaced it – the EA 2015.

In order to address this gap in the legal and regulatory framework of the ES, URCA published Consultation Document which put forward a proposal to reestablish and expand on those standards. In accordance with section 38(3)(g) of the EA 2015 URCA, through the consultation process, exercised its powers to issue standards. Specifically, the standard being discussed here covers;

- Power quality – the parameters (voltage, current, frequency, and harmonics ) within which the electricity supplied to consumer must comply.
- Reliability – the consistency with which electricity is supplied to consumers.

This Statement of Results and Final Decision now sets out the standard that governs power quality and reliability in electric power systems in The Bahamas.

## **1.2 Structure of the remainder of the Document**

The structure of the remainder of this document is as follows.

- Section 2: Summarizes the responses received to the Preliminary Consultation (ES 06/2023) and provides URCA's comments and final decision.
- Section 3: Outlines the major takeaways (conclusions) and next steps.
- Annex A: Contains the final version of the Standard for Power Quality and Reliability in Electric Power Systems in The Bahamas (ES 10/2023).

## **2. URCA’s responses to Comments received on the Consultation**

On 27 September 2023, URCA published the Consultation Document inviting comments from interested parties and the public. The period for submission of written responses and comments to the consultation document closed on 27 October 2023. During the consultation period, URCA received written responses from:

- The Bahamas Power and Light Company Limited (BPL)
- The Bahamas Telecommunications Company Limited (BTC)

URCA thanks the respondents for participating in the consultation process (see Annex B), and has sought to provide a summary of the responses considered and discussion of URCA’s position on those responses. However, URCA may not have reproduced all matters considered. The lack of response to a comment or any issue raised by a respondent does not signify URCA’s agreement in whole or in part with the comment, nor should it be taken to mean that URCA has not considered the comment or that the comment was unimportant or without merit.

In this section, URCA summarizes and responds to the substantive comments received on the consultation, as follows:

- Section 2.1 – General comments received on the consultation; and
- Section 2.2 – Specific responses to the consultation questions

### **2.1 General Comments**

All respondents (BTC and BPL) agreed with the overarching objective of the consultation to re-establish and improve on the “Standards for Power Quality and Reliability in Electric Power Systems” in The Bahamas. Most of the issues raised by BTC were not germane to the consultation. However, URCA took note of the issues for them to be addressed appropriately elsewhere. BPL’s primary concern was on the funding of the technology necessary to accurately capture and report on the data for the reliability indices. BPL’s concern is addressed in URCA’s response to question 2 below (section 2.2).

## 2.2 Specific Responses to the Consultation Questions

The format of this section takes the following sequence.

- The consultation question is provided (boxed in) with the same numbering used in the Consultation Document ES 06/2023,
- The comment(s) from the stakeholder(s),
- URCA's response to the stakeholder(s) comment(s),
- URCA's final decision on the matter.

Question 1: Are there any other relevant standards not included in this consultation document, which URCA ought to include?

### Stakeholder Comment(s)

BPL was of the view there are no other relevant standards necessary at this time.

### URCA's Response to Stakeholder Comment(s)

Noted.

### URCA's Final Decision

No change to the draft standard (ref. ES 06/2023).

Question 2: Is this [six months] a reasonable time for the implementation of the standards contained herein?



### Stakeholder Comment(s)

BPL did not think six months to implement the standards was reasonable due to the need to source and fund the technology to support the same. BPL did not give a timeframe. They suggested URCA accept estimated reliability indices.

### URCA's Response to Stakeholder Comment(s)

Maintaining an acceptable level of power quality is primarily a safety concern. In addition, delivery of electricity within prescribed parameters is necessary to ensure products available in the market and used by consumers function properly; hence, it also has economic implications. Licensees must be required to maintain power quality to a standard that ensures the electricity they supply to consumers is first of all safe and secondly fit for purpose.

URCA is generally aware that most, if not all, of the licensees may have difficulty providing the reliability data, mainly due to the type of metering installed at the customer level. Nevertheless, URCA considers this type of data key in providing information useful in firstly, improving licensees' performance (identifying problem areas) and secondly, in holding licensees accountable for poor performance. The status quo should not remain, and a path must be laid out towards full compliance. Licensees have the right to conduct a tariff review and submit a rate case to URCA. This option is relevant to those licensees who believe significant capital upgrades are required for compliance with the standard.

The lack of responses from the licensees, other than BPL, on the reliability matter makes it difficult for URCA to fully appreciate their ability to comply and hence make an informed decision.

### URCA's Final Decision

Licensees shall be required to maintain the power quality standards outlined in ES 06/2023.

URCA will forbear on the requirements outlined in Annex A, Section 6.5 Proposed Quality of Service Standards for Reliability in ES 06/2023 until it has completed an investigation as part of the determination process. After which, URCA will issue an Order.

Question 3: Do you agree with the definition of the Point of Common Coupling? If not, please provide an alternate definition with justification.

#### Stakeholder Comment(s)

BPL did not agree with the definition put forward in the Consultation and recommended the alternative definition below.

“Point of Common Coupling follows: The point where the electrical conductors of the utility’s distribution system are connected to the customer’s conductors and where any transfer of electric power between the customer and the distribution system takes place.”

#### URCA’s Response to Stakeholder Comment(s)

The reliability indices measure the continuity of service to the customer. Ideally data needed to calculate the indices will be gathered at the point where the utility supplies the customer – most often the metering point. The definition put forward by URCA was intended to reflect this. However, there is a great deal of similarity between URCA’s definition and BPL’s. URCA does not object to BPL’s definition and will amend the Standard to reflect the same.

#### URCA’s Final Decision

PCC will be amended in Section 2 – Definitions of the Standard to read as follows.

“Point of Common Coupling (PCC) means the point where the electrical conductors of the utility’s distribution system are connected to the customer’s conductors and where any transfer of electric power between the customer and the distribution system takes place. Typically, this is at the service meter.”

Question 4: Do you agree with the supply voltage limits proposed by URCA? Please give reasons why you do or do not agree with these limits and provide alternative limits. Please provide full reasoning in support of your response.

### Stakeholder Comment(s)

BPL stated the nominal voltage ranges listed in the Consultation should be expanded to include voltages that were allowed under the repealed “Electricity Act, CH 194 Rules”. Specific mention was made of some areas of Lyford Cay which is supplied at 240/415 volts.

### URCA’s Response to Stakeholder Comment(s)

Some of the voltages in the repealed Electricity Act (Ch. 194) and the Out Islands Electricity Act (CH. 195) are outdated. URCA understands the spirit of BPL’s recommendation. The standard is intended to meet the requirements of today’s electrical equipment. Furthermore, it will be the obligation of the licensee to, if required, provide the equipment, transformers for example, to convert any existing voltages to supply customers with the nominal voltages listed in the standard.

### URCA’s Final Decision

No change to the draft standard (ref. ES 06/2023).

Question 5: Do you agree with the allowable voltage deviation limits proposed by URCA? Please give reasons why you do or do not agree with these limits and provide alternative limits. Please provide full reasoning in support of your response.

### Stakeholder Comment(s)

BPL agreed.

### URCA’s Response to Stakeholder Comment(s)

Noted.

### URCA’s Final Decision

No change to the draft standard (ref. ES 06/2023).

Question 6: Do you agree with the allowable frequency deviations proposed by URCA? Please give reasons why you do or do not agree with these limits and provide alternative limits. Please provide full reasoning in support of your response.

Stakeholder Comment(s)

BPL agreed.

URCA's Response to Stakeholder Comment(s)

Noted.

URCA's Final Decision

No change to the draft standard (ref. ES 06/2023).

Question 7: Do you agree with the allowable harmonic limits proposed by URCA? Please give reasons why you do or do not agree with these limits and provide alternative limits. Please provide full reasoning in support of your response.

Stakeholder Comment(s)

BPL stated that customers should be held accountable for harmonics generated by their equipment that negatively impact the utility system. In addition, BPL did not agree with the allowable harmonic limits as there is no data on the current level of harmonics.

URCA's Response to Stakeholder Comment(s)

URCA agrees there is a bilateral obligation by both the utility and the customer in managing harmonics. A licensee's actions in relation to a customer that fails to remedy a situation for which that customer is alleged to be responsible that is alleged to cause a nuisance on the electrical

grid, on an individual case by case basis, would need to be considered and evaluated to ensure that the licensee's actions are reasonable and compliant with the law and applicable regulatory framework.

The standard for harmonics put forward by URCA is consistent with international standards (IEEE) as described in the Consultation. URCA considers these reasonable.

#### URCA's Final Decision

No change to the draft standard (ref. ES 06/2023).

Question 8: Do you agree that a recordable event should be any interruption that lasts more than 5 minutes? If not, please provide an alternative value with justification.

#### Stakeholder Comment(s)

BPL agreed.

#### URCA's Response to Stakeholder Comment(s)

Noted.

#### URCA's Final Decision

No change to the draft standard (ref. ES 06/2023).

Question 9: As a licensee, how will you comply with this requirement? For example, where and how will the event be recorded. [In the case of interruptions of service to the customer].

#### Stakeholder Comment(s)

BPL did not state how they will comply with the requirement. They raised the need capital investment.

URCA's Response to Stakeholder Comment(s)

See URCA's response under question 2 above.

URCA's Final Decision

See URCA's Final Decision under question 2 above.

Question 10: Do you agree with the proposed maximum SAIDI, SAIFI, CAIDI and ASAI values for New Providence proposed by URCA? Please give reasons why you do or do not agree with these limits and provide alternative limits. Please provide full reasoning in support of your response.

Stakeholder Comment(s)

BPL did not agree with the proposed minimum values. They contended that their current values are significantly above those proposed. They raised the need capital investment.

URCA's Response to Stakeholder Comment(s)

See URCA's response under question 2 above.

URCA's Final Decision

See URCA's Final Decision under question 2 above.

Question 11: Do you agree with the proposed maximum SAIDI, SAIFI, CAIDI and ASAI values for the Family Islands proposed by URCA? Please give reasons why you do or do not agree with these limits and provide alternative limits. Please provide full reasoning in support of your response.

Stakeholder Comment(s)

BPL did not agree with the proposed minimum values. They stated they have no data to determine if they can comply with the requirements. They raised the need capital investment.

URCA's Response to Stakeholder Comment(s)

See URCA's response under question 2 above.

URCA's Final Decision

See URCA's Final Decision under question 2 above.

### 3. Conclusions and Next Steps

URCA thanks both BTC and BPL for their participation in the Consultation Process. The comments received were valuable in forming the Final Decision on the matter. As a result of the process URCA has decided the standard as set out in the Consultation (ES 06/2023), Annex A, Section 6.5 Proposed Quality of Service Standards for Reliability, will be amended as follows.

- i. URCA will forbear on the requirements outlined in Annex A, Section 6.5 Proposed Quality of Service Standards for Reliability in ES 06/2023 until it has completed an investigation as part of the determination process. After which, URCA will issue an Order.
- ii. PCC will be amended in Section 2 – Definitions of the Standard to read as follows.

“Point of Common Coupling (PCC) means the point where the electrical conductors of the utility’s distribution system are connected to the customer’s conductors and where any transfer of electric power between the customer and the distribution system takes place. Typically, this is at the service meter.”

As a consequence of the above, URCA publishes the **“Standard for Power Quality and Reliability in Electric Power Systems”, ES 10/2023**, concurrently with this Statement of Results and Final Decision. For ease of reference this document is included in Annex A. The Standard for Power Quality and Reliability in Electric Power System, ES 10/2023 becomes effective on the date of publication. Licensed suppliers of electricity to the public shall incorporate this standard in their consumer protection plans. Failure to comply with the regulations may subject licensees to the enforcement provisions in the Electricity Act, any other relevant law, and regulatory or other measures.



# Annex A: Standard for Power Quality and Reliability in Electric Power Systems

## 1. Regulatory Title

This regulation may be cited as “Standard for Power Quality and Reliability in Electric Power Systems”.

## 2. Definitions

**APESL** means Approved Public Electricity Supplier Licensee as defined in Section 46(1)(a)(ii) of the EA.

**Abnormal Circumstances** means acts of force majeure where the usual operation of the electricity supplier is disrupted by factors beyond the control of the supplier such as during an extreme weather event.

**Consumer** means any person who uses or may use or requests or may request, a supply of energy for business or residential purposes, As defined in Part I, Preliminary, of the Electricity Act 2015.

**Customer** means, in relation to a licensee, the person –

- (a) to whom energy is supplied in the course of any business carried on as such by the licensee;
- (b) to whom the licensee is seeking to secure that energy is provided;
- (c) who wishes to be supplied with energy, or who is likely to seek to become a person to whom energy is supplied; and includes any of them whose use or potential use of energy is for the purposes of, or in connection with a business; as defined in Part I, Preliminary, of the Electricity Act 2015

**EA** means the Electricity Act of the Bahamas, enacted in 2015 as amended.

**Electrical Grid** or **Electricity Grid** means the electrical lines, conduits, or cables of any voltage level, providing electrical energy to a customer of the PESL or APESL and has the same meaning as “electricity supply system” as defined in *Part I, Preliminary*, of the Electricity Act 2015.

**Frequency** means the rate of oscillation of the electrical waveform every second. Frequency only applies to systems that use alternating current.

**Grid** means

- (a) any BPL power system, inclusive of transmission and distribution, wherever located within The Bahamas;
- (b) the power system, inclusive of transmission and distribution, of any public electricity supplier within The Bahamas other than BPL; as defined in Part I, Preliminary, of the Electricity Act 2015

**GTDS** means generation, transmission, distribution and supply (*of electrical energy*);

**Harmonic Distortion** means the interference in an AC power signal created by frequency multiples of the sine wave. Total Harmonic Distortion (THD) is used as a measure of the amount of harmonic distortion in the system.

**Point of Common Coupling (PCC)** means the point where the electrical conductors of the utility’s distribution system are connected to the customer’s conductors and where any transfer of electric power between the customer and the distribution system takes place. Typically, this is at the service meter.

**PESL** means Public Electricity Supplier Licensee as defined in Section 2 (Interpretation), of the EA.

**Phase Imbalance** means, in reference to a three-phase system, a mismatch in the line-to-line voltage of one or more conductors in that system. Three phase systems are intended to operate with phases balanced.

**Power Quality** means the condition of the electricity supply such that is in within the parameters specified in this consultation document and of such a condition so as to be safely and consistently used by customers without undue risk of damage to person or property.

**Voltage** means the amount of electrical pressure required or employed to effect the transfer of electrons (electrical current/energy) from one point in a conductor to another.

### **3. Measurement and Enforcement**

The term *power quality* refers to a wide variety of electromagnetic phenomena that characterize the voltage and current at a given time and at a given location on the power system. In verifying limits of power quality that may be supplied by a PESL or APESL, it is necessary to ensure compliance with those limits through the establishment of an adequate monitoring program.

#### **3.1 Measurement Regime**

The characteristics of the electrical system shall be measured using the equipment such as that described herein for the purpose of establishing ongoing and continued compliance of the electrical grid with the requirements of these regulations. The power quality parameters listed in this standard shall apply to, and be measured at, the point of common coupling.

URCA envisions that equipment described herein will, where necessary, be permanently installed at various points on the electrical grid and monitored and read by the licensee at regular intervals to verify compliance but in any case, not less than once per month for reporting purposes, or on receipt of a specific instructions by URCA.

#### **3.2 Equipment**

For the purposes of monitoring and reporting, the licensee is required to utilize its own equipment to monitor compliance and act where necessary. It shall also provide the data to URCA in the manner and format specified. URCA may inspect the licensee's equipment to verify its accuracy and / or request the licensee to do the same and provide the results of such inspection to URCA.

As a check of the reported values, URCA may establish a contemporaneous monitoring program utilizing, inter alia, the following tools and equipment to monitor licensee electrical power quality:

#### **Power Quality Analyzers**

Power quality analyzers are devices that measure and record power quality parameters such as voltage, current, harmonics, and transients.

#### **Power Quality Meters**

Power quality meters are used for long-term monitoring of power quality parameters and will be installed at a specific location to monitor the electrical signals continuously.

#### **Data Loggers**

Data loggers are used for monitoring voltage variations, current fluctuations, and other power quality parameters at high speed and with high accuracy.

#### **Power Quality Monitoring Systems**

These tools provide a comprehensive approach to power quality monitoring and will include sensors and analyzers to monitor and track the quality of the power supply.

#### **Other Special tools**

URCA may use any other tool or equipment device, or process not specifically referred to in this document to ensure compliance with the power quality levels described herein.

### **3.3 Enforcement**

Enforcement is an on-going regulatory obligation and a necessary outflow of the establishment of technical standards. When implementing enforcement measures, URCA will do so for the benefit of all stakeholders to enforce regulated sector laws, encourage competition, and to ensure that licensees are compliant with the license conditions and other technical rules and regulations published by URCA.

Enforcement is a necessary component of regulation to ensure the integrity of the electrical supply system. The enforcement framework therefore includes both ex-ante and ex-post regulatory measures intended to allow URCA to prevent, detect and investigate electrical supply issues. As part of enforcement a licensee may, among other remedies, be subject to a fine for a breach.

### **3.4 Inspections**

URCA, acting in accordance with section 40(6) of the Electricity Act, has the right to monitor and enforce the consumer protection conditions in licenses and, in this regard, URCA may from time to time appoint in writing one or more suitably qualified electrical inspectors to inspect;

- (a) any electrical installation or apparatus of BPL or of any other public electricity supplier; or,
- (b) the wirings, fittings or apparatus used by any consumer.

This statutory provision provides URCA with the legislative underpinning to ensure that electrical systems are established, operated, and maintained in a manner that is consistent with regulatory standards.

## **4. Nominal Supply Levels**

Public Electricity Supplier Licensees (PESL) and Approved Public Electricity Supplier Licensees (APESL) shall supply their service at the following voltages and frequencies, unless alternative levels are agreed between the licensee and customer.

Table 1 Allowable Supply Voltages and Frequencies

Distribution	Voltage (Volts)	Phases	Frequency (Hz)
Level A	120	1	60
Level B	120/240	1	60
Level C	120/208	3	60
Level D	277/480	3	60

## 5. Allowable Deviation to Nominal Supply Levels

### 5.1 Voltage Deviation

The steady state supply voltage shall be maintained within plus or minus six percent (+/- 6%) of the nominal supply level.

### 5.2 Allowable Voltage Phase Imbalance

The maximum phase imbalance, measured under no load conditions, shall be limited to plus or minus three percent (+/- 3%).

$$\text{Percent voltage unbalance} = \frac{V_{\max \text{ dif}} - V_{\text{av } 3 \text{ ph}}}{V_{\text{av } 3 \text{ ph}}} * 100\%$$

Where:

$V_{\max \text{ dif}}$  = the phase voltage with the largest difference from the average of the three phases.

$V_{\text{av } 3 \text{ ph}}$  = the average voltage of the three phases

### 5.3 Frequency Deviation

The steady state supply frequency shall be maintained within plus or minus two percent (+/- 2%) of the nominal supply level.

### 5.4 Harmonic Deviation

Harmonics are produced both by the system operator and the end user. The harmonic currents produced by the end user flow through the owner's or operator's system which leads to voltage harmonics in the voltages supplied to other users. Both the licensee and the customer have a responsibility to limit harmonic currents.

URCA recognizes the impact that the addition of harmonic adding equipment can have on the system and encourages system operators to advise consumers of these effects and to not add equipment that affects the impedance characteristics in a way such that the voltage distortions are increased. Also, system operators shall make every effort to minimize the harmonics produced and supplied to end users and transmitted to the grid from end users.

At the PCC, system owners or operators shall limit line-to-neutral voltage harmonics as follows:

- Daily 99th percentile very short time (3 s) values shall be less than 1.5 times the values given in Table 2.
- Weekly 95th percentile short time (10 min) values shall be less than the values given in Table 2.

All values shall be in percent of the rated power frequency voltage at the PCC. Table 2 applies to voltage harmonics whose frequencies are integer multiples of the power frequency up to and including the 50<sup>th</sup> harmonic.

The limits in this clause are based on the fact that some level of voltage distortion is generally acceptable <sup>4</sup>and the underlying assumption of these limits is that by limiting harmonic current

---

<sup>4</sup> IEEE Std 519 – 2022 Clause 5 para 1

injections by users, voltage distortion can be kept below objectionable levels. In the event that limiting harmonic currents alone does not result in acceptable levels of voltage distortion, system owners or operators should take action to modify system characteristics so that voltage distortion levels are acceptable. The acceptable voltage distortion levels form the basis of the harmonic voltage limits in table 2.

Table 2: Allowable Harmonics<sup>5</sup>

Level	Bus Voltage at PCC	Individual Harmonic (%) $h \leq 50$	Total Harmonic Distortion THD (%)
A	$V \leq 1.0 \text{ kV}$	5.0	8.0

---

<sup>5</sup> IEEE Std 519 – 2022 table 1 – voltage distortion limits ( $V \leq 1.0 \text{ kV}$ )



## 6. Reliability

### 6.1 Definitions, acronyms, and abbreviations

#### 6.1.1 Definitions

For the purposes of this standard reliability indices shall mean those parameters when measured, recorded, and reported track the *consistency* of supply of the electrical grid. And the following event definitions shall apply.

**Interruption:** An interruption is the total loss of electric power on one or more normally energized conductors to one or more customers connected to the distribution portion of the system.

**Interruption duration:** The time period from the initiation of an interruption until service has been restored to the affected customers.

#### 6.1.2 Acronyms and Abbreviations

The following parameters are used in the calculation of performance indices:

<b>CI</b>	Customers Interrupted
<b>CMI</b>	Customer Minutes of Interruption
<b>K</b>	Number of interruptions experienced by an individual customer in the reporting period.
<b>L<sub>i</sub></b>	Connected kVA load interrupted for each interruption event
<b>L<sub>T</sub></b>	Total connected kVA load served
<b>N<sub>i</sub></b>	Number of interrupted customers for each sustained interruption event during the reporting period
<b>N<sub>mi</sub></b>	Number of interrupted customers for each momentary interruption event during the reporting period
<b>N<sub>T</sub></b>	Total number of customers served for the area
<b>r<sub>i</sub></b>	Restoration time for each interruption event
<b>T<sub>MED</sub></b>	Major Event Day threshold

## 6.2 Recording and Reporting of Indices

A recordable event is any interruption that lasts more than 5 minutes

The indices shall be measured, recorded and reported to URCA by PESL and APESL as referenced in the licensees' reporting requirements e.g. outage reporting and biannual reports.

## 6.3 Reliability Indices

### 6.3.1 System Average Interruption Duration Index (SAIDI)

SAIDI indicates the total duration of interruption for the average customer during a pre-defined period of time. It is commonly measured in hours of interruption. A sample calculation of SAIDI is shown below:

$$SAIDI = \frac{\Sigma \text{ Customer Minutes of Interruption}}{\text{Total Number of Customers Served}}$$

To calculate SAIDI, the following formula is used:

$$SAIDI = \frac{\Sigma r_i N_i}{N_T} = \frac{CMI}{N_T}$$

### 6.3.2 System Average Interruption Frequency Index (SAIFI)

The System Average Interruption Frequency Index (SAIFI) indicates how often the average customer experiences a sustained interruption over a predefined period of time as represented in the equation below.

$$SAIFI = \frac{\Sigma \text{ Total Number of Customers Interrupted}}{\text{Total Number of Customers Served}}$$

To Calculate SAIFI, the following formula is used:

$$SAIFI = \frac{\sum N_i}{N_T} = \frac{CI}{N_T}$$

### 6.3.3 Customer Average Interruption Duration Index (CAIDI):

The Customer Average Interruption Duration Index (CAIDI) represents the average time required to restore service. It is represented by the equation below:

$$CAIDI = \frac{\Sigma \text{ Customer Minutes of Interruption}}{\text{Total Number of Customers Interrupted}} = \frac{CMI}{CI}$$

To Calculate CAIDI, the following formula is used:

$$CAIDI = \frac{\sum r_i N_i}{\sum N_i} = \frac{SAIDI}{SAIFI}$$

### 6.3.4 Average System Availability Index (ASAI):

The Average System Availability Index Average System Availability Index (ASAI) measures the percentage of time a customer receives an electricity service over a defined period (e.g. monthly/yearly). It is calculated as follows:

$$ASAI = \frac{\text{Customer Hours of Service Demanded}}{\text{Customer Hours of Service Provided}}$$

ASAI can also be calculated numerically from either of the following equations:

$$ASAI = 1 - \left( \frac{\sum(r_i * N_i)}{(N_T * T)} \right) * 100 = \left( \frac{8760 - SAIDI}{8760} \right) * 100$$

Where

T = Time Period being monitored (hours)

R<sub>i</sub> = restoration time (hours)

N<sub>i</sub> = total number of customers interrupted

$N_t$  = Total number of customers served.

ASAI directly measures the generation and system adequacy and complements the other reliability indices. Additionally, the ASAI measure requires no additional information for computation. Together, these indices provide comprehensive indicators of the reliability performance of the electricity network.

### **6.3.5 Major Event Day (MED) Definition**

It is important to define a further term which is useful in tracking of reliability indices in the supply of electrical power. That term is a Major Event Day. A Major Event Day is a day in which the daily system SAIDI exceeds the threshold value, TMED. The SAIDI index is used as the basis of this definition since it leads to consistent results regardless of utility size, and because SAIDI is a good indicator of operational and design stress. Even though SAIDI is used to determine the MEDs, all indices should be calculated based on removal of the identified day.<sup>6</sup>

URCA does not propose that Major Event Days be tracked by PESL and APESL, at this time, but intends, by introducing the terminology, to make licensees aware of the term, and its utility in conjunction with SAIDI as an indicator of operational and design stress.

A major event day can also be used as a classification of major outages. URCA notes that such a definition was recently determined by URCA (ES 01 /2023) but signals its intent to introduce the new definition once licensees have attained necessary familiarity of and facility with the terms introduced in this standard.

## **6.4 Sample Calculations of SAIFI, SAIDI and CAIDI**

The table below is used to calculate the referenced indices. In the example the utility serves 2000 customers in the geographical area.

---

<sup>6</sup> IEEE Std 1366-2022 IEEE Guide for Electric Power Distribution Reliability Indices

Table 3 Interruption Data for Electric Utility 2022

Event Number	Date	Time Off	Time On	Duration (min)	Number of Customers Affected	Interruption Type
1	Jan 7	12:12:20	12:20:30	8.17	200	S
2	Feb 2	18:23:56	18:24:26	0.5	400	M
3	Mar 15	00:23:10	01:34:29	71.32	600	S
4	May 12	23:17:00	23:47:14	30.23	25	S
5	Jun 6	09:30:10	09:31:10	1	2,000	M
6	Aug 15	15:45:39	20:12:50	267.18	90	S
7	Sep 31	08:20:00	10:20:00	120	700	S
8	Oct 18	17:10:00	17:20:00	10	1,500	S
9	Nov 21	10:15:00	10:55:00	100	100	S
		Note 1: Interruption type S = Sustained; M = Momentary Note 2: Total Customers Served = 2000				

From Table 3: the number of customers who have experienced a sustained interruption is 3, 215. The total number of customers who have sustained a momentary interruption is 2,400.

These technical standards do not require the reporting of momentary interruptions, but they are included here for the guidance of licensees in the calculation of the indices.

Calculation of SAIFI

$$SAIFI = \frac{200 + 600 + 25 + 90 + 1500 + 100}{2000} = 1.61$$

Calculation of SAIDI

$$SAIDI = \frac{(8.17 \times 200) + (71.3 \times 600) + (30.3 \times 25) + (267.2 \times 90) + (120 \times 700) + (10 \times 1500) + (40 \times 100)}{2000} = 86.11 \text{ minutes}$$

or 1.43 hours

Calculation of CAIDI

$$CAIDI = \frac{SAIDI}{SAIFI} = \frac{86.110}{1.6075} = 53.57 \text{ minutes}$$

Calculation of ASAI

$$ASAI = \left( \frac{8760 - SAIDI}{8760} \right) * 100 = \left( \frac{8760 - 1.435}{8760} \right) * 100 = 99.98\%$$

## 6.5 Quality of Service Standards for Reliability

Licenseses shall incorporate the following quality of service standards into their Consumer Protection Plans:

Table 4 Proposed Reliability Indicator Targets for New Providence

Parameter	Units (Per Year Per Customer)	Reliability Indicator Targets		
		2024	2025	2026
SAIDI <sup>(1)</sup>	Hours	4.25	4.16	4.07
SAIFI <sup>(1)</sup>	Outages	6.24	6.12	5.99
CAIDI <sup>(1)</sup>	Hours	0.68	0.68	0.68
ASAI <sup>(2)</sup>	Percentage	99.951	99.952	99.953

**Notes:**

- 1) Values for SAIDI, SAIFI and CAIDA are maximum values
- 2) Values for ASAI are minimum values.

Table 5 Proposed Reliability Indicator Targets for The Family Islands

Parameter	Units (Per Year Per customer)	Targets		
		2024	2025	2026
SAIDI <sup>(1)</sup>	Hours	6.25	6.12	5.99
SAIFI <sup>(1)</sup>	Outages	8.24	8.07	7.91
CAIDI <sup>(1)</sup>	Hours	0.76	0.76	0.76
ASAI <sup>(2)</sup>	Percent	99.928	99.930	99.932

**Notes:**

- 1) Values for SAIDI, SAIFI and CAIDA are maximum values
- 2) Values for ASAI are minimum values.

# **Annex B: Submissions Received to the Public Consultation ES 06/2023**

Submissions were received from the following entities.

1. Bahamas Telecommunication Company (BTC), 26 October 2023
2. Bahamas Power and Light Company Limited (BPL), 27 October 2023